

## West Bengal Renewable Energy Development Agency

(An Organisation of Deptt. of Power & NES, Govt. of West Bengal)  
Bikalpa Shakti Bhawan, Plot no.: J1/10, EP & GP Block, Sector-V  
Electronics Complex Salt Lake, Kolkata-700091

### Minutes of the Meetings

NIeT No.: WBREDA/NIeT-032014-15  
Pre-Bid meeting held on 22/10/14 at 12.00 noon

Memo No: WBREDA/ SPV-SLS/23/

Dated:28/10/14

The pre-bid meeting held on 22.10.2014 at 12.00 noon as per schedule of the NIeT at the office of WBREDA, Bikalpa Shakti Bhavan, 1st Floor, Conference Room, Salt Lake, Kolkata-700091, to discuss on the Bidding Document in connection with the tender for Manufacture, supply and installation of 4000 nos. LED based Solar PV Street Lighting Systems in the State of West Bengal, w.r.t. NIeT No.: WBREDA/NIeT-03/2014-15- Meeting started in presence of the intending bidders.

Director-in-Charge, WBREDA chaired the meeting and initiated the discussion. At the outset, he explained the intension and spirit of this project and then invited comments from attended intending bidders on the Bidding Document.

The careful consideration of all the proposals, the following modification have been made, which shall now be treated as part of the Tender Document.


Head	Mentioned in NIeT	Amendment/Explanation/Addendum
In General throughout the NIeT	i) OPTION - I	i) Read as TYPE-I
	ii) OPTION-II	ii) Read as TYPE-II
	iii) BOQ-I	iii) Explanation: BOQ-I related to TYPE-II
	iv) BOQ-II	iv) Explanation: BOQ-II related to TYPE-I
Exemption of EMD	NSIC units registered in West Bengal are exempted from submission of Earnest Money as per their eligibility	NSIC units registered only for Solar PV business in West Bengal are exempted from submission of Earnest Money as per their eligibility
<b>ALL bidders must filled up both the BOQ (I &amp; II) under Type-I and Type -II systems</b>		
BOQ under Tender ID no:- 2014_WBRED_25649_1	Mentioned in option-II Qty is 250 nos. (Now Type-II)	Qty will be 500 nos. Read as Type -II( with Low maintenance Lead Acid Battery & 4.55mtrs pole height )
BOQ under Tender ID no:- 2014_WBRED_25649_2	Mentioned in option-I: Qty is 250/500nos. (Now Type-I).	Qty will be 500 nos. Read as Type -I (with T-gel Battery & 4mtrs height pole )
<b>CATEGORY-I</b>	Certificate is to be attached/ up loaded in accordance with since 2011-12	One certificate is to be attached / up loaded in accordance with since 2010-11
<b>Under eligibility criteria (Credential) Sl. no. ( C ) of 02</b>		
<b>Under eligibility criteria (Credential) Sl. no. ( b ) of 02</b>	Financial capability 1.0(one) crore and above in last three years (11-12,12-13,13-14) in SPV business with continuation of business.	Financial capability 1.0 (one) crore and above in last three years in totally (11-12,12-13,13-14) in SPV business with continuation of business
<b>CATEGORY-II (NEW VENDORS)</b>	New Vendors will not have to deposit any EMD initially.	For validation of offer an amount of Rs. 1000.00 (rupees one thousand only) have to be submitted in the form of banker's cheque or Bank Draft in favour of WBREDA.
<b>Under Provision for Induction of New vendor vis-à-vis vendor</b>		


Development	No price would be quoted under BOQ-I & II. In case they offered their price, their application will be treated as cancelled.	For validation of tendering process, New vendors under Category- II have to submit both the BOQ (I & II) putting amount Rs.1.00. This amount will not be treated as a 'token amount' and not the actual price offered, which will be settled later on as mentioned else in this tender
<b>Under Credential:</b>		
Test Reports of Solar PV Systems	Test reports of Solar PV Systems any of the following SPV-SLS /SPV-HLS/Lantern, (ii) For the power plant	The bidder shall submit the Valid test certificate of SPV-SLS/ SPV-HLS from MNRE approved test lab since 2010-11
<b>Non-Statutory Cover</b>	A) - Vi) Last three financial years balance sheet	Certificate is to be attached / uploaded in accordance with balance sheet duly certified by Chattered Accountant Firm.
	A)-vii) Copy of the trade License for the year 13-14 or 14-15	A-vii) Trade License for the year 2014-15 is to only attached
	A)viii) Not mentioned	A)viii) One Test certificate of SLS from MNRE approved Test Lab since 2010-11
<b>Under Special Terms and Conditions;</b> Sl. No:- 12.0 Maintenance service during warranty and CMC period	Each system should be attended at least once in every <b>four months</b> to check up and routine maintenance and the report shall be authenticated by the users and <b>WBREDA official</b> quarterly.	Each system should be attended at least once in every <b>three months</b> to check up and routine maintenance and the report shall be authenticated by the users quarterly.
<b>Under Technical Specification:</b> Sl. No. 5.0- Option II	Size of Pole: OD- 3.0" X L-4.0mtrs. OD-2.5" X L-1.55mtrs.	Size of Pole: OD-3.0" X L-3.00mtrs. OD-2.5" X L-1.55mtrs.
Sl. 31.	For BOQ II; WBREDA ..... work <b>one</b> acceptable L1 bidder price	Read as <b>on the L1 bidder price</b>
Sl. 31. (Under N.B)	competition	Read as Completion
<b>Technical Specification under serial no: ( b) of 2.0</b>	The power of output of the module under STC should be a minimum of max	The power output of the module under STC should be a minimum of 74Wp

No further observations or clarifications were raised during the meeting.

Memo no.: WBREDA/ SPV- SLS/23/706(2)  
Copy forwarded for information to:

1. Accounts-in-Charge
- ✓ 2. Copy for uploading in the e-tender portal of the website <http://wbtenders.gov.in>

  
Director-in-Charge  
Date 28/10/14

  
Director-in-Charge